

AIR FILTRATION
& AIR QUALITY



HEPALAM-150-ARM

Laminar Flow Absolute Filters

APPLICATIONS

To be used for absolute air filtration in controlled contamination environments clean rooms, LAF benches and operating rooms

FILTER CODE STRUCTURE

Type	HL	HEPALAM
Class EN 1822	11	E11
Frame	A	A: Aluminum
Media	R	R: Micro Glass Fibre Y: High Heat (Max. 120 °C)
Pleat Depth	M	K: 48 mm M: 58 mm N: 75 mm L: 100 mm E: 135 mm
Surface Grid	2	0: Without Grid 1: Face Grid Air Outlet 2: Both Side with Grid
Gasket Type	P	X: Without Gasket P: Polyurethane R: Rubber E: EPDM Y: High Heat
Gasket Direction	G	X: No C: Air Outlet G: Air Inlet W: Both Side
Size	0610-0610-150	

TECHNICAL SPECIFICATIONS

Class EN 1822	E10	E11	E12	H13	H14	U15
Av. Efficiency EN 1822	≥85%	≥95%	≥99.5%	≥99.95%	≥99.995%	≥99.9995%
Max. Temperature	80°C (Optional 120 °C)					
Relative Humidity	100 %					
Rec. Final Pres. Drop	600 Pa.					
Filter Stage	III - IV					

For more information please click here.

