

AIR FILTRATION  
& AIR QUALITY



## HEPALAM-69-ARK

Laminar Flow Absolute Filters

### FILTER CODE STRUCTURE

Type	<b>HL</b>	HEPALAM-69
Class EN1822	<b>12</b>	E12
Frame	<b>A</b>	A: Aluminum
Media	<b>R</b>	R: Micro Glass Fibre Y: High Heat (Max. 120 °C)
Pleat Depth	<b>K</b>	K: 48 mm
Surface Grid	<b>2</b>	0: Without Grid 1: Face Grid Air Outlet 2: Both Side with Grid
Gasket Type	<b>P</b>	X: Without Gasket P: Polyurethane R: Rubber E: EPDM Y: High Heat
Gasket Direction	<b>G</b>	X: No C: Air Outlet G: Air Inlet W: Both Side
Size	0610-0610-069	

### APPLICATIONS

To be used for absolute air filtration in controlled contamination environments clean rooms, LAF benches and operating rooms

### TECHNICAL SPECIFICATIONS

Class EN1822	E10	E11	E12	H13	H14	U15
Av. Efficiency EN1822	≥85%	≥95%	≥99.5%	≥99.95%	≥99.995%	≥99.9995%
Max. Temperature	80°C (Optional 120°C)					
Relative Humidity	100%					
Rec. Final Pres. Drop	600 Pa.					
Filter Stage	III - IV					

For more information please click here. 

