

AIR FILTRATION
& AIR QUALITY



HEPALAM-78-ARM

Laminar Flow Absolute Filters

APPLICATIONS

To be used for absolute air filtration in controlled contamination environments clean rooms, LAF benches and operating rooms

FILTER CODE STRUCTURE

Type	HL	HEPALAM-78
Class EN1822	11	E11
Frame	A	A: Aluminum
Media	R	R: Micro Glass Fibre Y: High Heat (Max. 120 °C)
Pleat Depth	M	K: 48 mm M: 58 mm
Surface Grid	2	0: Without Grid 1: Face Grid Air Outlet 2: Both Side with Grid
Gasket Type	P	X: Without Gasket P: Polyurethane R: Rubber E: EPDM Y: High Heat
Gasket Direction	G	X: No C: Air Outlet G: Air Inlet W: Both Side
Size		0610-0610-078

TECHNICAL SPECIFICATIONS

Class EN1822	E10	E11	E12	H13	H14	U15
Av. Efficiency EN1822	≥85%	≥95%	≥99.5%	≥99.95%	≥99.995%	≥99.9995%
Max. Temperature	80°C (Optional 120 °C)					
Relative Humidity	100%					
Rec. Final Pres. Drop	600 Pa.					
Filter Stage	III - IV					

For more information please click here.

