

AIR FILTRATION  
& AIR QUALITY



## HEPALAM-90-ARM

Laminar Flow Absolute Filters

### APPLICATIONS

To be used for absolute air filtration in controlled contamination environments clean rooms, LAF benches and operating rooms

### FILTER CODE STRUCTURE

Type	<b>HL</b>	HEPALAM-90
Class EN 1822	<b>11</b>	E11
Frame	<b>A</b>	A: Aluminum
Media	<b>R</b>	R: Micro Glass Fibre Y: High Heat (Max. 120 °C)
Pleat Depth	<b>M</b>	K: 48 mm    M: 58 mm
Surface Grid	<b>2</b>	0: Without Grid 1: Face Grid Air Outlet 2: Both Side with Grid
Gasket Type	<b>P</b>	X: Without Gasket    P: Polyurethane R: Rubber    E: EPDM Y: High Heat
Gasket Direction	<b>G</b>	X: No    C: Air Outlet    G: Air Inlet W: Both Side
Size		0610-0610-90

### TECHNICAL SPECIFICATIONS

Class EN1822	E10	E11	E12	H13	H14	U15
Av. Efficiency EN1822	≥85%	≥95%	≥99.5%	≥99.95 %	≥99.995 %	≥99.9995 %
Max. Temperature	80°C (Optional 120 °C)					
Relative Humidity	100 %					
Rec. Final Pres. Drop	600 Pa.					
Filter Stage	III - IV					

For more information please click here.

